

# CRAWFORD CO RWD 1C

## Consumer Confidence Report – 2024

### Covering Calendar Year – 2023



This brochure is a snapshot of the water quality we provided last year. Included are the details about where your water comes from, what it contains, and how it compares to the Environmental Protection Agency (EPA) and state standards. We are committed to providing you with information because informed customers are our best allies. If you would like to observe the decision-making process that affect drinking water quality, please call JUSTIN MCATEE at 620-249-6145.

Our drinking water is supplied from another water system through a Consecutive Connection (CC). Your water comes from 3 Ground Water Well(s):

Buyer Name	Seller Name
CRAWFORD CO RWD 1C	PUBLIC WHOLESALE WSD 11

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as those with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. The EPA's Safe Drinking Water Hotline (800-426-4791) can provide more information about contaminants and potential health effects.

The sources of drinking water (both tap water and bottled water) included rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before we treat it include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides may come from various sources such as storm water run-off, agriculture, and residential users.

Radioactive contaminants, which can be naturally occurring or the result of mining activity.

Organic contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also come from gas stations, urban storm water run-off, and septic systems.

To ensure that tap water is safe to drink, the EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Our water system is required to test a minimum of 2 samples per month in accordance with the Total Coliform Rule for microbiological contaminants. Coliform bacteria are usually harmless, but their presence in water can be an indication of disease-causing bacteria. When coliform bacteria are found, special follow-up tests are done to determine if harmful bacteria are present in the water supply. If this limit is exceeded, the water supplier must notify the public.

#### Water Quality Data

The following tables list all of the drinking water contaminants which were detected during the 2023 calendar year. The presence of these contaminants does not necessarily indicate the water poses a health risk. Unless noted, the data presented in this table is from the testing done January 1- December 31, 2023. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old. **The bottom line is that the water that is provided to you is safe.**

#### Terms & Abbreviations

**Maximum Contaminant Level Goal (MCLG):** the "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to human health. MCLGs allow for a margin of safety.

**Maximum Contaminant Level (MCL):** the "Maximum Allowed" MCL is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Secondary Maximum Contaminant Level (SMCL):** recommended level for a contaminant that is not regulated and has no MCL.

**Action Level (AL):** the concentration of a contaminant that, if exceeded, triggers treatment or other requirements.

**Treatment Technique (TT):** a required process intended to reduce levels of a contaminant in drinking water.

**Maximum Residual Disinfectant Level (MRDL):** the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Non-Detects (ND):** lab analysis indicates that the contaminant is not present.

**Parts per Million (ppm):** or milligrams per liter (mg/l)

**Parts per Billion (ppb):** or micrograms per liter (µg/l)

**Picocuries per Liter (pCi/L):** a measure of the radioactivity in water.

**Millirems per Year (mrem/yr):** measure of radiation absorbed by the body.

**Monitoring Period Average (MPA):** An average of sample results obtained during a defined time frame, common examples of monitoring periods are monthly, quarterly and yearly.

**Nephelometric Turbidity Unit (NTU):** a measure of the clarity of water.

Turbidity in excess of 5 NTU is just noticeable to the average person. Turbidity is not regulated for groundwater systems.

**Running Annual Average (RAA):** an average of sample results obtained over the most current 12 months and used to determine compliance with MCLs.

**Locational Running Annual Average (LRAA):** Average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

## Testing Results for Consolidated Rural Water District No. 1, Crawford County

Regulated Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
ARSENIC	1/31/2022	1.2	1.2	ppb	10	0	Erosion of natural deposits
BARIUM	1/31/2022	0.055	0.055	ppm	2	2	Discharge from metal refineries
FLUORIDE	1/31/2022	0.7	0.7	ppm	4	4	Natural deposits; Water additive which promotes strong teeth.
SELENIUM	1/31/2022	4.3	4.3	ppb	50	50	Erosion of natural deposits

Disinfection Byproducts	Monitoring Period	Highest RAA	Range (low/high)	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	2023	10	4 - 18	ppb	60	0	By-product of drinking water disinfection
TTHM	2023	13	5.8 - 23	ppb	80	0	By-product of drinking water chlorination

Lead and Copper	Monitoring Period	90 <sup>th</sup> Percentile	Range (low/high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2023	0.22	0.014 - 0.24	ppm	1.3	0	Corrosion of household plumbing
LEAD	2023	1.2	0 - 3.9	ppb	15	0	Corrosion of household plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Chlorine/Chloramines Maximum Disinfection Level	MPA	MPA Units	RAA	RAA Units
2023 - 2023	2.6000	MG/L	2.6	MG/L

Unresolved Deficiency Date Identified	Facility	Comments
11/09/2023	WATER SYSTEM	Crawford CO RWD 1C had their Bacteriological Sampling Site Plan and map as required, but the map and list of addresses were outdated. According to Kansas Administrative Regulation (K.A.R.) 28-15a-21 each bacteriological water sample shall be taken at a point which is representative of the condition within the distribution system and in accordance with a written sampling site plan. The district is required to update their sampling site plan, develop a map and submit copies to this office.
11/09/2023	WATER SYSTEM	K.A.R. 28-15-18(c) requires public water supplies to prepare and maintain an Emergency Water Supply Plan. It is recommended that utilities annually review and update their Emergency Water Supply Plan. Crawford CO RWD 1C's Emergency Water Supply Plan contains outdated emergency contact information. KDHE requests that your facility review and update your current Emergency Water Supply Plan. Once the plan has been reviewed and updated, please submit a revised copy to our office for review.
11/09/2023	STORAGE TANK 01	All water storage structures including; underground, ground level, clearwells or elevated storage tanks are required to have properly installed non-corrodible screens which protect the quality of the water. The district operator is required to inspect all of the district's water storage structure's vents and overflow pipes ensuring screens are present. To correct the deficiency the operator is required to submit to me, a list of all the storage structures documenting the present or absences of screens on the vents and overflow pipes. If screens are missing the operator is required to replace the missing screens and submit photo documentation to my office.

Radiological Contaminants	Collection Date	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	10/10/2023	4.7	2.2 - 4.7	PCI/L	5	0	Erosion of natural deposits

Continued on next page

Secondary Contaminants-Non Health Based Contaminants-No Federal Maximum Contaminant Level (MCL) Established.	Collection Date	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	1/31/2022	230	230	MG/L	300
CALCIUM	1/31/2022	81	81	MG/L	200
CHLORIDE	1/31/2022	950	950	MG/L	250
CONDUCTIVITY @ 25 C UMHO/CM	1/31/2022	1100	1100	UMHO/CM	1500
CORROSIVITY	1/31/2022	0.59	0.59	LANG	0
HARDNESS, TOTAL (AS CaCO3)	1/31/2022	350	350	MG/L	400
MAGNESIUM	1/31/2022	37	37	MG/L	150
MANGANESE	1/31/2022	0.0019	0.0019	MG/L	0.05
NICKEL	1/31/2022	0.0034	0.0034	MG/L	0.1
PH	1/31/2022	7.8	7.8	PH	8.5
POTASSIUM	1/31/2022	8.3	8.3	MG/L	100
SILICA	1/31/2022	12	12	MG/L	50
SODIUM	1/31/2022	140	140	MG/L	100
SULFATE	1/31/2022	89	89	MG/L	250
TDS	1/31/2022	710	710	MG/L	500
ZINC	1/31/2022	0.037	0.037	MG/L	5

During the 2023 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period	Analyte	Comments
10/1/2023 - 12/31/2023	TOTAL HALOACETIC ACIDS (HAA5)	MONITORING, ROUTINE (DBP), MAJOR
10/1/2023 - 12/31/2023	TTHM	MONITORING, ROUTINE (DBP), MAJOR

There are no additional required health effects notices.

There are no additional required health effects violation notices.

Some or all of our drinking water is supplied from another water system. The table below lists all of the drinking water contaminants, which were detected during the 2023 calendar year from the water systems that we purchase drinking water from.

Regulated Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	MCL	MCLG	Typical Source
BARIUM	4/11/2023	PUBLIC WHOLESale WSD 11	0.048	0.048	ppm	2	2	Discharge from metal refineries

Secondary Contaminants	Collection Date	Water System	Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, TOTAL	4/11/2023	PUBLIC WHOLESale WSD 11	94	94	MG/L	300
ALUMINUM	4/11/2023	PUBLIC WHOLESale WSD 11	0.21	0.21	MG/L	0.05
CALCIUM	4/11/2023	PUBLIC WHOLESale WSD 11	43	43	MG/L	200
CHLORIDE	4/11/2023	PUBLIC WHOLESale WSD 11	12	12	MG/L	250
CONDUCTIVITY @ 25 C UMHO/CM	4/11/2023	PUBLIC WHOLESale WSD 11	260	260	UMHO/CM	1500
CORROSIVITY	4/14/2021	PUBLIC WHOLESale WSD 11	0.069	0.069	LANG	0
HARDNESS, TOTAL (AS CaCO3)	4/11/2023	PUBLIC WHOLESale WSD 11	130	130	MG/L	400
MAGNESIUM	4/11/2023	PUBLIC WHOLESale WSD 11	4.8	4.8	MG/L	150
NICKEL	4/11/2023	PUBLIC WHOLESale WSD 11	0.003	0.003	MG/L	0.1
PH	4/11/2023	PUBLIC WHOLESale WSD 11	7.9	7.9	PH	8.5
PHOSPHORUS, TOTAL	4/11/2023	PUBLIC WHOLESale WSD 11	0.24	0.24	MG/L	5
POTASSIUM	4/11/2023	PUBLIC WHOLESale WSD 11	2.9	2.9	MG/L	100
SODIUM	4/11/2023	PUBLIC WHOLESale WSD 11	4.1	4.1	MG/L	100
SULFATE	4/11/2023	PUBLIC WHOLESale WSD 11	21	21	MG/L	250
TDS	4/11/2023	PUBLIC WHOLESale WSD 11	140	140	MG/L	500

Please Note: Because of sampling schedules, results may be older than 1 year.

During the 2023 calendar year, the water systems that we purchase water from had the below noted violation(s) of drinking water regulations.